

Control # 050020110817

Date Taken 08/17/2011

Service Meter Reading 0

Fluid Run Time 0

Fluid Added Gal / Qts 0 / 0

Fluid Status Sampled

Filter Changed Unknown

BS&W % Volume 0.1000



**Lab One Inc.**

Oil Analysis since 1985

Mail to: PO Box 20210 - Phoenix, AZ 85036-0210

Ship to: 101 W Mohave St. - Phoenix AZ 85003

Phone

Local: 480-839-5221

Toll Free: 866-652-2663

Fax: 480-839-9987

**Reportable**

1 of 1

07/01/2014

**Make / Model**

**Unit/Serial**

DIESEL FUEL/

**Compartment**

Diesel Fuel

**Fluid Type**


**WO / Reference**

**Current Interpretation**

BS&W results above ASTM specifications. Recommend check for source of contamination.

000000084

Lab One Web Test  
Attn: Jason Kronlund  
101 West Mohave Street  
Phoenix, AZ 85003



Registered By: **JASON KRONLUND**

Interpreted By: **JASON KRONLUND**

For additional sample history visit us at [www.LabOneInc.com](http://www.LabOneInc.com)